

EU TYPE-EXAMINATION CERTIFICATE (MODULE B)

REGULATION (EU) 2016/426

This is to certify that the appliances listed have been examined and found to comply with the essential requirements listed in the **Regulation (EU) 2016/426** of the European Parliament and of the council of 9 March 2016 on appliances burning gaseous fuels (Annex I).

To demonstrate full compliance with the Regulation (EU) 2016/426, a "Conformity to Type" Module C2 or D or E or F is required.

Applicant: Riello S.p.A.

Via Ing. Pilade Riello, 7- 37045 (VR) - Italy

Trade Mark: Beretta

Product Type: Central heating combi condensing boiler

Models: METEO X 25C, METEO X 30C

Certificate N°: ITS-2575-GAR-213194801-R1

PIN: 2575DM28897

This certificate only relates to those products detailed in the following Test Reports:

Report Number: 200028897UDI-GCE-RCE-R8

Certificate Issue date:

23 January 2023

Certificate Expiry date:

28 March 2032

Michael Albert Gandin

Certification Manager Intertek Italia SpA (NB 2575)



PRD N° 277B

Membro degli Accordi di Mutuo Riconoscimento EA, IAF e ILAC

Signatory of EA, IAF and ILAC Mutual Recognition Agreements



This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.



PRODUCT DESCRIPTION

PRODUCT TYPE: Central heating combi condensing boiler

MODELS: METEO X 25C

STANDARD(S): EN 15502-1:2021, EN 15502-1:2012+A1:2015 and EN 15502-2-1:2012+A1:2016

SPECIAL REMARKS: Minimum ambient temperature > -15°C

APPLIANCES TYPE: B_{23P}, B_{53P}, C₍₁₀₎, C₁₃, C₃₃, C₄₃, C₅₃, C₆₃, C₈₃, C₉₃, C_{13x}, C_{33x}, C_{43x}, C_{53x}, C_{63x}, C_{83x}, C_{93x}

The gas categories for which the appliances have been tested can be obtained by combining the following countries and gas groups:

COUNTRIES: AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV,

MK, MT, NO, NL, PL, PT, RO, SE, SI, SK, TR

GAS GROUP, REFERENCE GAS AND SUPPLY PRESSURES:

| GROUP | REFERENCE GAS | GROUP | REFERENCE GAS | GROUP | REFERENCE GAS |
|-------|---------------|-------|---------------------|-------|---------------|
| Н | G20 – 20 mbar | М | G230 – 20 mbar | Р | G31 – 30 mbar |
| Н | G20 – 25 mbar | Y20 | G20.2 – 20 mbar (*) | Р | G31 – 37 mbar |
| E | G20 – 20 mbar | | | Р | G31 – 50 mbar |

(*) Y20 - Gas group not yet introduced in EN 437 based on a gas composition of Methan/Hydrogen (CH4 = 80% / H2 = 20%)



PRODUCT TYPE: Central heating combi condensing boiler

MODELS: METEO X 30C

STANDARD(S): EN 15502-1:2021, EN 15502-1:2012+A1:2015 and EN 15502-2-1:2012+A1:2016

SPECIAL REMARKS: Minimum ambient temperature > -15°C

APPLIANCES TYPE: $B_{23P},\,B_{53P},\,C_{(10)},\,C_{13},\,C_{33},\,C_{43},\,C_{53},\,C_{63},\,C_{83},\,C_{93},\,C_{13x},\,C_{33x},\,C_{43x},\,C_{53x},\,C_{63x},\,C_{83x},\,C_{93x}$

The gas categories for which the appliances have been tested can be obtained by combining the following countries and gas groups:

COUNTRIES: AL, AT, BE, BG, CH, CY, CZ, DE, DK, EE, ES, FI, FR, GB, GR, HR, HU, IE, IS, IT, LT, LU, LV,

MK, MT, NO, NL, PL, PT, RO, SE, SI, SK, TR

GAS GROUP, REFERENCE GAS AND SUPPLY PRESSURES:

| GROUP | REFERENCE GAS | GROUP | REFERENCE GAS |
|-------|----------------------|-------|----------------------|
| Н | G20 – 20 mbar | E(R) | G20/G25 – 20/25 mbar |
| Н | G20 – 25 mbar | E(S) | G20/G25 – 20/25 mbar |
| E | G20 – 20 mbar | Lw | G27 – 20 mbar |
| Esi | G20/G25 – 20/25 mbar | Ls | G2.350 – 13 mbar |
| Er | G20/G25 – 20/25 mbar | М | G230 – 20 mbar |
| ELL | G20/G25 – 20 mbar | Y20 | G20.2 – 20 mbar (*) |

| GROUP | REFERENCE GAS | | | |
|-------|---------------|--|--|--|
| Р | G31 – 30 mbar | | | |
| Р | G31 – 37 mbar | | | |
| Р | G31 – 50 mbar | | | |
| | | | | |
| | | | | |
| | | | | |

^(*) Y20 – Gas group not yet introduced in EN 437 based on a gas composition of Methan/Hydrogen (CH4 = 80% / H2 = 20%)

REVISION AND COMMENTS

| DD/MM/YYYY | AMENDED BY | PRJ NO. | REPORT NO. | REASON FOR REVISION |
|------------|-------------|---------|-------------------------|--|
| 29/03/2022 | M.A. Gandin | 31948 | 200028897UDI-GCE-RCE-R4 | RO: First issue |
| 23/01/2023 | M.A. Gandin | 35443 | 200028897UDI-GCE-RCE-R8 | R1: Verification according to EN 15502-1:2021 and introduction of new gas categories |



EC TYPE-EXAMINATION CERTIFICATE (MODULE B)

DIRECTIVE 92/42/EEC

This is to certify that, with reference to the Council **Directive 92/42/EEC** of 21 May 1992 on efficiency requirements for new hot-water boilers fired with liquid or gaseous fuels and according to article 4 of commission regulation (EU) No. 813/2013, the appliances listed have achieved the full and part load efficiencies written on Annex 1.

To demonstrate full compliance with the Directive 92/42/EEC, a "Conformity to type" Module C or D or E is required.

Applicant: Riello S.p.A.

Via Ing. Pilade Riello, 7-37045 (VR) - Italy

Trade Mark: Beretta

Product Type: Central heating combi condensing boiler

Models: METEO X 25C, METEO X 30C

Certificate N°: ITS-2575-BED-213194801

PIN: 2575DM28897

Standard(s): EN 15502-1:2012+A1:2015 and EN 15502-2-1:2012+A1:2016

This certificate only relates to those products detailed in the following Test Reports:

Report Number: 200028897UDI-GCE-RCE-R4



Certificate Issue date:

29 March 2022

Michael Albert Gandin

Certification Manager Intertek Italia SpA (NB 2575)



PDR Nº 277B

Membro degli Accordi di Mutuo Riconoscimento EA, IAF e ILAC

Signatory of EA, IAF and ILAC Mutual Recognition Agreements



This Certificate is for the exclusive use of Intertek's client and is provided pursuant to the agreement between Intertek and its Client. Intertek's responsibility and liability are limited to the terms and conditions of the agreement. Intertek assumes no liability to any party, other than to the Client in accordance with the agreement, for any loss, expense or damage occasioned by the use of this Certificate. Only the Client is authorized to permit copying or distribution of this Certificate and then only in its entirety. Any use of the Intertek name or one of its marks for the sale or advertisement of the tested material, product or service must first be approved in writing by Intertek.



ANNEX 1

| Models: | | | |
|-----------------------|-------------|-------------|--|
| | METEO X 25C | METEO X 30C | |
| η ₁₀₀ | 97,3 % | 97,3 % | |
| η ₃₀ | 108,5 % | 109,0 % | |
| η ₄ | 87,6 % | 87,6 % | |
| η_1 | 97,7 % | 98,2 % | |
| P ₄ | 19,5 kW | 24,4 kW | |
| P ₁ | 6,5 kW | 8,2 kW | |
| C.Heater | Yes | Yes | |
| B ₁ Boiler | No | No | |
| Type of boiler: | Condensing | Condensing | |
| Range Rated? | Yes | Yes | |

Note

 η_{100} = At rated heat output and high-temperature regime - NCV (*) - EN15502-1 clause 9.5.2.1: "the useful efficiency at nominal heat input Qn or for range rated boilers at the arithmetic mean of the maximum and minimum heat input Qa"

 η_{30} = At 30 % of rated heat output and low-temperature regime - NCV (**) - EN15502-1 clause 9.5.2.1: "the useful efficiency at 30 % of the nominal heat input Qn or for range rated boilers at 30 % of the arithmetic mean of the maximum and minimum heat input Qa"

 η_4 = At rated heat output and high-temperature regime (*)

 η_1 = At 30 % of rated heat output and low-temperature regime (**)

P₄ = At rated heat output and high-temperature regime (*)

 P_1 = At 30 % of rated heat output and low-temperature regime (**)

C.Heater = Combination Heater (Yes = with domestic hot water production / No = Heating system only)

B1 Boiler = B1 according CEN/TR 1749:2014

Type of boiler:" Condensing Boiler" or "Low Temperature Boiler" or Other Boiler"

(*) High-temperature regime means 60 °C return temperature at heater inlet and 80 °C feed temperature at heater outlet.

(**) Low temp. means for condensing boilers 30 °C, for low-temp. boilers 37 °C and for other heaters 50 °C return temperature (at heater inlet).

(n.t. = not tested; n.a. = not applicable)

REVISION AND COMMENTS

| DD/MM/YYYY | AMENDED BY | PRJ NO. | REPORT NO. | REASON FOR REVISION |
|------------|-------------|---------|-------------------------|---------------------|
| 29/03/2021 | M.A. Gandin | 31948 | 200028897UDI-GCE-RCE-R4 | RO: First issue |